

STATE OF MONTANA  
DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION  
1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

# GENERAL ABSTRACT

**Water Right Number:** 41F 58320-00 PROVISIONAL PERMIT  
**Version:** 1 -- ORIGINAL RIGHT

**Version Status:** ACTIVE

**Owners:** WEST YELLOWSTONE, TOWN OF  
% SUPERINTENDENT OF PUBLIC SERVICES  
PO BOX 1570  
WEST YELLOWSTONE, MT 59758-1570

**Priority Date:** JANUARY 9, 1985 at 03:15 P.M.

**Enforceable Priority Date:** JANUARY 9, 1985 at 03:15 P.M.

**Purpose (use):** MUNICIPAL

**Maximum Flow Rate:** 760.00 GPM

**Maximum Volume:** 300.00 AC-FT

**Source Name:** GROUNDWATER

**Source Type:** GROUNDWATER

**Point of Diversion and Means of Diversion:**

<u>ID</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1		E2SW	27	13S	5E	GALLATIN

**Period of Diversion:** JANUARY 1 TO DECEMBER 31

**Diversion Means:** WELL

**Purpose (Use):** MUNICIPAL

**Volume:** 300.00 AC-FT

**Period of Use:** JANUARY 1 to DECEMBER 31

**Place of Use:**

<u>ID</u>	<u>Acres</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1			SW	27	13S	5E	GALLATIN

**Remarks:**

**GROUNDWATER WASTE & CONTAMINATION**

THIS RIGHT IS SUBJECT TO SECTION 85-2-505, MCA, REQUIRING A WELL BE CONSTRUCTED SO IT WILL NOT ALLOW WATER TO BE WASTED OR CONTAMINATE OTHER WATER SUPPLIES OR SOURCES, AND A FLOWING WELL MUST BE CAPPED OR EQUIPPED SO THE FLOW OF THE WATER MAY BE STOPPED WHEN NOT BEING PUT TO BENEFICIAL USE.

**GROUNDWATER WELL - ACCESS PORT**

THE FINAL COMPLETION OF THE WELL(S) MUST INCLUDE AN ACCESS PORT OF AT LEAST .50 INCH SO THE STATIC LEVEL OF THE WELL MAY BE ACCURATELY MEASURED.

**IMPORTANT INFORMATION**

THIS SYSTEM CONSISTS OF A SERIES OF MANIFOLD WELLS WITH A COMBINED WELL YIELD NOT TO EXCEED 760 GPM.

**WATER MEASUREMENT INFORMATION (OLD)**

THE APPROPRIATOR SHALL KEEP A WRITTEN RECORD OF THE FLOW RATE AND VOLUME OF ALL WATERS DIVERTED, INCLUDING THE PERIOD OF TIME, AND SHALL SUBMIT SAID RECORDS UPON REQUEST TO THE WATER RESOURCES REGIONAL OFFICE LISTED BELOW. BOZEMAN, MT PH: 406-586-3136 FAX: 406-587-9726

**WATER MEASUREMENT INFORMATION (OLD)**

THE APPROPRIATOR SHALL INSTALL AN ADEQUATE FLOW METERING DEVICE TO ALLOW THE FLOW RATE AND VOLUME OF WATER DIVERTED TO BE RECORDED.

**PROGRESS REPORT REQUIRED**

THE APPROPRIATOR SHALL SUBMIT A PROGRESS REPORT OF THE WORK COMPLETED UNDER THIS RIGHT BY NOVEMBER 30TH OF EACH YEAR UNTIL COMPLETION OF THE PROJECT. SUBMIT REPORTS TO THE WATER RESOURCES REGIONAL OFFICE LISTED BELOW. BOZEMAN, MT PH: 406-586-3136 FAX: 406-587-9726