

STATE OF MONTANA
DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION
1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

GENERAL ABSTRACT

Water Right Number: 41H 100663-00 PROVISIONAL PERMIT
Version: 1 -- ORIGINAL RIGHT
Version Status: ACTIVE

Owners: BOZEMAN, CITY OF
%TIM COOPER, ATTY
PO BOX 1230
BOZEMAN, MT 59771-1230

Priority Date: JANUARY 15, 1997 at 11:14 A.M.

Enforceable Priority Date: JANUARY 15, 1997 at 11:14 A.M.

Purpose (use): IRRIGATION

Maximum Flow Rate: 60.00 GPM

Maximum Volume: 6.78 AC-FT

Maximum Acres: 3.60

Source Name: GROUNDWATER

Source Type: GROUNDWATER

Point of Diversion and Means of Diversion:

<u>ID</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1		SWNE	10	2S	5E	GALLATIN

Period of Diversion: APRIL 15 TO OCTOBER 15

Diversion Means: WELL

Subdivision: VALLEY UNIT SUB PHASE 1 BLOCK: 28

Well Depth: 60.00 FEET

Static Water Level: 4.00 FEET

Casing Diameter: 6.00 INCHES

Pump Size: 5.00 HP

Purpose (Use): IRRIGATION

Irrigation Type: SPRINKLER

Volume: 6.78 AC-FT

Period of Use: APRIL 15 to OCTOBER 15

Place of Use:

<u>ID</u>	<u>Acres</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1	3.60		W2E2NE	10	2S	5E	GALLATIN

Subdivision: VALLEY UNIT SUB PHASE 1 BLOCK: 28

Total: 3.60

Remarks:

Remarks:

GROUNDWATER WASTE & CONTAMINATION

THIS RIGHT IS SUBJECT TO SECTION 85-2-505, MCA, REQUIRING A WELL BE CONSTRUCTED SO IT WILL NOT ALLOW WATER TO BE WASTED OR CONTAMINATE OTHER WATER SUPPLIES OR SOURCES, AND A FLOWING WELL MUST BE CAPPED OR EQUIPPED SO THE FLOW OF THE WATER MAY BE STOPPED WHEN NOT BEING PUT TO BENEFICIAL USE.

GROUNDWATER WELL - ACCESS PORT

THE FINAL COMPLETION OF THE WELL(S) MUST INCLUDE AN ACCESS PORT OF AT LEAST .50 INCH SO THE STATIC LEVEL OF THE WELL MAY BE ACCURATELY MEASURED.

WATER MEASUREMENT-WATER USE MEASURING DEVICE

THE APPROPRIATOR SHALL INSTALL A DEPARTMENT APPROVED WATER USE MEASURING DEVICE AT A POINT APPROVED BY THE DEPARTMENT TO ALLOW THE FLOW RATE AND VOLUME OF WATER DIVERTED TO BE RECORDED. WATER MUST NOT BE DIVERTED UNTIL THE REQUIRED MEASURING DEVICE IS IN PLACE AND OPERATING. ON A FORM PROVIDED BY THE DEPARTMENT, THE APPROPRIATOR SHALL KEEP A WRITTEN YEARLY RECORD OF THE FLOW RATE AND VOLUME MEASUREMENTS AND SHALL SUBMIT THE RECORDS BY NOVEMBER 30 OF EACH YEAR AND UPON REQUEST AT OTHER TIMES DURING THE YEAR. FAILURE TO SUBMIT REPORTS MAY BE CAUSE FOR REVOCATION OR MODIFICATION OF A PERMIT OR CHANGE. THE RECORDS MUST BE SUBMITTED TO THE WATER RESOURCES REGIONAL OFFICE. CONTACT THE REGIONAL OFFICE TO OBTAIN THE CURRENT ADDRESS. THE APPROPRIATOR SHALL MAINTAIN THE MEASURING DEVICE SO IT ALWAYS OPERATES PROPERLY AND MEASURES FLOW RATE ACCURATELY. BOZEMAN - PH: 406-586-3136 FAX: 406-587-9726

WATER MEASUREMENT - ANNUAL DATA

MEASUREMENT DATA: 1998 00060.00 GPM 00000.01 AC-FT