

STATE OF MONTANA
DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION
1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

GENERAL ABSTRACT

Water Right Number: 76H 103828-00 PROVISIONAL PERMIT
Version: 1 -- ORIGINAL RIGHT

Version Status: ACTIVE

Owners: CORVALLIS SCHOOL DISTRICT #1
PO BOX 700
CORVALLIS, MT 59828

Priority Date: MAY 28, 1998 at 08:00 A.M.

Enforceable Priority Date: MAY 28, 1998 at 08:00 A.M.

Purpose (use): INSTITUTIONAL
THIS RIGHT WILL SERVE THE JUNIOR HIGH AND HIGH SCHOOL BUILDINGS. IT WILL NOT BE USED FOR IRRIGATION.

Maximum Flow Rate: 120.00 GPM

Maximum Volume: 15.00 AC-FT

Source Name: GROUNDWATER

Source Type: GROUNDWATER

Point of Diversion and Means of Diversion:

<u>ID</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1		SENESE	32	7N	20W	RAVALLI

Period of Diversion: JANUARY 1 TO DECEMBER 31

Diversion Means: WELL

Well Depth: 136.00 FEET

Static Water Level: 16.00 FEET

Casing Diameter: 8.00 INCHES

Pump Size: 7.50 HP

Purpose (Use): INSTITUTIONAL

Volume: 15.00 AC-FT

Period of Use: JANUARY 1 to DECEMBER 31

Place of Use:

<u>ID</u>	<u>Acres</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1			SENESE	32	7N	20W	RAVALLI

Remarks:

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

23713-00 103828-00

ASSOCIATED RIGHT

THIS RIGHT IS ASSOCIATED TO 76H-C-023713. THEY HAVE OVERLAPPING PLACES OF USE.

WATER MEASUREMENT-INLINE FLOW METER REQUIRED

THE APPROPRIATOR SHALL INSTALL A DEPARTMENT APPROVED IN-LINE FLOW METER AT A POINT IN THE DELIVERY LINE APPROVED BY THE DEPARTMENT TO RECORD THE FLOW RATE AND VOLUME OF WATER DIVERTED. WATER MUST NOT BE DIVERTED UNTIL THE REQUIRED MEASURING DEVICE IS IN PLACE AND OPERATING. ON A FORM PROVIDED BY THE DEPARTMENT, THE APPROPRIATOR SHALL KEEP MONTHLY WRITTEN RECORDS OF THE FLOW RATE AND VOLUME MEASUREMENTS AND SHALL SUBMIT THE RECORDS BY NOVEMBER 30 OF EACH YEAR AND UPON REQUEST AT OTHER TIMES DURING THE YEAR. FAILURE TO SUBMIT REPORTS MAY BE CAUSE FOR REVOCATION OR MODIFICATION OF A PERMIT OR CHANGE. THE RECORDS MUST BE SENT TO THE WATER RESOURCES REGIONAL OFFICE. CONTACT THE REGIONAL OFFICE FOR THE CURRENT ADDRESS. THE APPROPRIATOR SHALL MAINTAIN THE MEASURING DEVICE SO IT ALWAYS OPERATES PROPERLY AND MEASURES FLOW RATE ACCURATELY. MISSOULA - PH: 406-721-4284 FAX: 406-542-1496