

STATE OF MONTANA  
DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION  
1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

# GENERAL ABSTRACT

**Water Right Number:** 42M 30062767 PROVISIONAL PERMIT  
**Version:** 1 -- ORIGINAL RIGHT  
**Version Status:** ACTIVE

**Owners:** MONTANA H2O LLC  
1411 22ND AVE NW  
SIDNEY, MT 59270

**Priority Date:** FEBRUARY 17, 2012 at 11:20 A.M.  
**Enforceable Priority Date:** FEBRUARY 17, 2012 at 11:20 A.M.

**Purpose (use):** WATER MARKETING  
**Maximum Flow Rate:** 363.00 GPM  
**Maximum Volume:** 585.00 AC-FT

**Source Name:** GROUNDWATER  
**Source Type:** GROUNDWATER

**Point of Diversion and Means of Diversion:**

<u>ID</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1		SESENW	22	23N	59E	RICHLAND

**Period of Diversion:** JANUARY 1 TO DECEMBER 31  
**Diversion Means:** WELL  
**Well Depth:** 70.00 FEET

**Purpose (Use):** WATER MARKETING **Purpose Clarification:** INDUSTRIAL  
**Volume:** 585.00 AC-FT  
**Period of Use:** JANUARY 1 to DECEMBER 31

**Place of Use:**

<u>ID</u>	<u>Acres</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1			SESENW	22	23N	59E	RICHLAND

**Geocodes/Valid:** 27-3444-22-2-01-04-0000 - Y

**Remarks:**

**ASSOCIATED RIGHT**

PERMIT 42M 30062767 AND 42M 30066155 ARE ASSOCIATED. THEY SHARE THE SAME PLACE OF USE. 42M 30066155 IS FOR AN ADDITIONAL WELL TO INCREASE THE FLOW RATE. THE COMBINED APPROPRIATION IS 750 GPM UP TO 585 ACRE-FEET PER ANNUM.

**GROUNDWATER WASTE & CONTAMINATION**

THIS RIGHT IS SUBJECT TO SECTION 85-2-505, MCA, REQUIRING ALL WELLS BE CONSTRUCTED SO THEY WILL NOT ALLOW WATER TO BE WASTED OR CONTAMINATE OTHER WATER SUPPLIES OR SOURCES, AND ALL FLOWING WELLS SHALL BE CAPPED OR EQUIPPED SO THE FLOW OF THE WATER MAY BE STOPPED WHEN NOT BEING PUT TO BENEFICIAL USE.

**GROUNDWATER WELL - ACCESS PORT**

THE FINAL COMPLETION OF THE WELL(S) MUST INCLUDE AN ACCESS PORT OF AT LEAST .50 INCH SO THE STATIC LEVEL OF THE WELL MAY BE ACCURATELY MEASURED.

**IMPORTANT INFORMATION**

ACCESS AT THE DEPOT SHALL BE CONTROLLED ENSURING ONLY THOSE USERS WITH CONTRACTS ARE ABLE TO ACQUIRE WATER.

**IMPORTANT INFORMATION**

THE APPROPRIATOR SHALL SUBMIT A PROGRESS REPORT OF THE WORK COMPLETED UNDER THIS RIGHT BY NOVEMBER 30TH OF EACH YEAR AND UPON REQUEST AT OTHER TIMES DURING THE YEAR UNTIL COMPLETION OF THE PROJECT. FAILURE TO SUBMIT REPORTS MAY BE CAUSE FOR REVOCATION OF THE PERMIT. THE REPORTS MUST BE SENT TO THE GLASGOW WATER RESOURCE OFFICE.

**IMPORTANT INFORMATION**

WATER APPROPRIATED UNDER THIS PERMIT SHALL NOT BE TRANSPORTED OUTSIDE THE STATE OF MONTANA. CUSTOMERS SHALL BE INFORMED OF THIS CONDITION BY LANGUAGE INCLUDED IN THE

---

**Remarks:**

CONTRACT AND BY SIGNS POSTED AT THE DEPOT.

**REISSUED RIGHT**

THE RIGHT ISSUED ON 10/02/2012 WAS REISSUED. THE RIGHT WAS REISSUED BECAUSE THE PROJECT COMPLETION NOTICE DUE DATE WAS CORRECTED.

**WATER MEASUREMENT-INLINE FLOW METER REQUIRED**

THE APPROPRIATOR SHALL INSTALL A DEPARTMENT APPROVED IN-LINE FLOW METER AT A POINT IN THE DELIVERY LINE APPROVED BY THE DEPARTMENT. WATER MUST NOT BE DIVERTED UNTIL THE REQUIRED MEASURING DEVICE IS IN PLACE AND OPERATING. ON A FORM PROVIDED BY THE DEPARTMENT, THE APPROPRIATOR SHALL KEEP A WRITTEN MONTHLY RECORD OF THE FLOW RATE AND VOLUME OF ALL WATER DIVERTED, INCLUDING THE PERIOD OF TIME. RECORDS SHALL BE SUBMITTED BY NOVEMBER 30 OF EACH YEAR AND UPON REQUEST AT OTHER TIMES DURING THE YEAR. FAILURE TO SUBMIT REPORTS MAY BE CAUSE FOR REVOCATION OF A PERMIT OR CHANGE. THE RECORDS MUST BE SENT TO THE WATER RESOURCES REGIONAL OFFICE. THE APPROPRIATOR SHALL MAINTAIN THE MEASURING DEVICE SO IT ALWAYS OPERATES PROPERLY AND MEASURES FLOW RATE AND VOLUME ACCURATELY.

**WATER MEASUREMENT-INLINE FLOW METER REQUIRED**